

Opportunity Wisdom



Jonnie Beavers, Superintendent
Krystle Lowrey, Bookkeeper

Daniel Brooks, Principal
Chrissy Wiig, Secretary

Learning Success

Remediation Plan Recommendations

For test points at or above 5 ppb lead content, per §160.077, secure water and discontinue use until remediated unless testing proves that flushing will provide water below 5ppb.

27 Test points were identified;

The 3 points listed below all indicated greater than 5parts per billion during the initial draw sampling phase.

- 1 The kitchen scullery sprayer on the dish sink was remediated successfully through cleaning, replacing or filtering.
- 2 showers were exempted based on updated guidance from DHSS/CDC.

If you desire further health information, you can contact your county health department:

harrisoncountyhealthdept.org

Harrison County Health Department

1700 Bethany Ave, Bethany, MO 64424

[\(660\) 425-6324](http://(660) 425-6324)

Congratulations on completing this round of lead testing! The next cycle begins on the first day of school in the 28/29 school year.

Lab results are available on the school website.

Initial	Flush	Remedial	Location	STATUS
9.46	ND	1.85	KITCHEN SCULLERY SPRAYER	SUCCESSFULLY REMEDIATED
7.26	ND	*	SHOWER IN GIRLS LOCKER ROOM	EXEMPT
6.68	ND	*	SHOWER IN BOYS LOCKER ROOM	EXEMPT